

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7300-1615:180

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

DESIGN: Models DX4020 and D9133TTL-E Network Interface Modules; Models C900TTL-E and *C900V2 Dialer Capture Modules. Units are intended for use with Model D6600 receiver for capturing alarm and event data from dialer based alarm control panels. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 V dc nominal

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed Model D6600 DACR (CSFM Listing No. 7300-1615:179) and Models D7212, D7412, D9112, D9412, D7212G, D7412G or D9412G fire alarm control units. Models C900TTL-E and *C900V2 may also be used with separately listed compatible fire alarm control units. Approved for central station fire alarm signaling only. Refer to listee's Installation Instruction Manual for details.

FORMERLY: 7300-0801:212

*Rev. 10-04-2005 jew



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division